

CERTIFICATE OF CONFORMITY

Certificate number

No: 2619/0335-CER

Holder & Manufacturer

NingBo Deye Inverter Technology Co., Ltd.

No. 26 South YongJiang Road, Dagi, Beilun, NingBo, China

Trademark

Deye Tech. Group Deve 德業

Tested model

SUN-12K-G03

Variant models

SUN-5K-G03 / SUN-6K-G03 / SUN-7K-G03 / SUN-8K-G03 / SUN-10K-G03 / SUN-15K-G03 /

SUN-18K-G03

Type of generating unit

Utility Interactive Inverter

Technical Data

Nominal Power [kW]

15

Nominal Voltage [V]

Nominal Frequency [Hz]

Firmware version

Number of phases

Isolation transformer

18

3W / PE 400 50 / 60

Display software version: Ver 0208 Control software version: Ver 1813

Three phase

NO

This certificate of conformity confirms that one sample of the above-mentioned product is in compliance with:

- IEC 60068-2-1:2007. Environmental testing. Part 2-1: Tests. Test Ae: Cold.
- IEC 60068-2-2:2007. Environmental testing. Part 2-2: Tests. Test Be: Dry heat.
- IEC 60068-2-14:2009. Environmental testing. Part 2-14: Tests. Test Nb: Change of temperature.
- IEC 60068-2-30:2005. Environmental testing. Part 2-30: Tests. Test Db-Variant 1: Damp heat, cyclic (12 h + 12 h cycle).
- IEC 61683:1999. Photovoltaics systems Power conditioners Procedure for measuring efficiency.
- IEC 62116:2014. Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
- IEC 61727:2004. Photovoltaics (PV) systems Characteristics of the utility interface

This certificate of conformity is based upon the test results of the test reports number below detailed and is only valid when the product is manufactured in accordance with the tested sample.

- 2219 / 0335 A for IEC 61727:2004
- 2219 / 0335 B for IEC 62116:2014
- 2219 / 0335 C for IEC 60068-2-1:2007; IEC 60068-2-2:2007; IEC 60068-2-14:2009; IEC 60068-2-30:2005
- 2219 / 0335 D for IEC 61683:1999

This certificate will expire in 5 years from the release date of these test reports, issued the 23rd of October of 2019.

Madrid, 25th of October 2019



Certification Manager SGS Tecnos, S.A. C/ Trespaderne, 29 - 28042 Madrid

Daniel Arranz Muñiz

This certificate is issued by SGS under its General Conditions for Product Certification at The status and validity of the certificate can be checked scanning the QR code above included or through the following web link database: This document cannot be reproduced partially

Nº 2619/0335-CER Page 1 of 1